



Double-rail access aid

9635011

GTIN: 4007126034335

EN 14396 requires that access aids (holding devices) are installed in shafts. Projection at least 1 m above the surface. The shaft must have a minimum depth of 1.60 m, since the entry aid can not be completely sunk!

Material

Stainless steel 1.4301 / AISI 304

Rail dimension | Width

40 x 20 mm | 300 mm

Specifications

lowerable	✓
For mounting on the ladder	✓
Material	Stainless steel 1.4301 / AISI 304
Width in mm	300
Rail dimension	40 x 20 mm
Rail dimension Width	40 x 20 mm 300 mm

